



MICHAEL D. THOMPSON
Fire Chief

FIRE DEPARTMENT

CITY OF CULVER CITY

9770 CULVER BOULEVARD, CULVER CITY, CALIFORNIA 90232-0507

FIRE PREVENTION BUREAU

(310) 253-5925

FAX (310) 253-5824

PAUL FRANCIS
Fire Marshal

September 16, 1999

PLEASE POST

REMINDER

Production Cast & Crew,

The Culver Fire Department wants to remind you that all requirements of the **CALIFORNIA FIRE CODE** and the **CULVER CITY MUNICIPAL CODE** will be strictly enforced. Especially the following:

1. **Aisles (Fire lanes).** Perimeter aisles within the sound stage shall be provided. Aisles required by this section shall have a **minimum width of 4 feet.**

-Sec. 4004.2, 1998 California Fire Code

2. **Smoking.** No smoking is allowed on stage unless it is part of the film production.

-Sec. 1109.4, 1998 California Fire Code

Unless permitted by the Fire Chief, any person violating any of the provisions or failing to comply with any of the requirements of the Fire Code shall be guilty of a misdemeanor and upon conviction thereof, shall be punishable in accordance with Sections 1-10 and 1-10.1 of this (Culver City Municipal) Code.

Serving you,

RICHARD G. MOMII
Asst. Fire Marshal/Sr. Inspector